

Methodology:

- Identification of the HVAC load pattern and energy consumption of the HVAC system.
- Identification of the optimum thermal energy storage required and cost-effective technology to be used for the storage.
- Evaluation of the economic benefits to the industry and to the utility.

2. Identification of the HVAC Load Pattern and Energy Consumption of the HVAC System.

HVAC system consumes around 60% of its total electricity consumption in a large hotel [5]. Further analysis shows that 30% to 40% of electricity consumption of the HVAC system is from the central plant which consists of chillers and cooling towers. Break down of electrical energy use in a typical hotel building is given in Figure 1 [4].




Figure 1 - Breakdown of Electricity Consumption of a Large Hotel

Existing HVAC system of Cinnamon Lakeside hotel consists of one 455 TR Single Screw DAIKIN Chiller and two 300 TR cooling towers and several pumps and fan coil units.

Two 300 TR cooling towers are operating at their full capacity throughout the day and each cooling tower is rated 7.5 kW at full load.

2.1. Average Load Profile of the Chiller Plant of Cinnamon Lakeside Hotel

Figure 2 shows the average load profile of the chiller at Cinnamon Lakeside Hotel. The average load profile of the chiller shows that there is a possibility of shifting cooling load to off peak hours as there is a low demand in the

off-peak hours compared to the peak and day hours. The utility defines “Day” period as from 05.30 hours to 18.30 hours, “Peak” period as from 18.30 hours to 22.30 hours and “Off-Peak” period as from 22.30 hours to 05.30 hours for Time of Use (TOU) tariff.




Figure 2 - Average Electrical Load Profile of Chiller

2.2. Data Analysis

Breakdown of the average energy consumption per day of chiller and cooling towers in TOU time slots are shown in Figure 3.




Figure 3 - Average Energy Consumption per Day of Chiller and Cooling Towers

A Ton of Refrigeration (TR) is a unit of power used to describe the heat extraction capacity of refrigeration and air conditioning equipment. It is defined as the rate of heat transfer that results in the melting of 1 short ton (2,000 lb.; 907 kg) of pure ice at 0 °C in 24 hours. Equations 1 and 2 show the relationships among parameters kW_R , CIP, kW_e and TR.

$$kW_R = COP \times kW_e \quad \dots(1)$$

$$TR = kW_R / 3.51 \quad \dots(2)$$

where:

kW_e = kilowatt (electrical)

kW_R = kilowatt (cooling)

COP = Coefficient of Performance

Table 1 - Breakdown of Load Profile

	Off Peak (22.30 - 05.30)	Day (05.30 - 18.30)	Peak (18.30 - 22.30)	Total
Energy (kWh)	1,048.9	3,156.9	821.3	5,027.1
Cooling Load (kW _{ch})	5,926.2	17,836.7	4,640.1	28,403.0
Cooling Load (TR _h)	1,688.4	5,081.7	1,322.0	8,092.0

2.3. Methods of Air Conditioning Load Shifting

A Chilled Water Storage System (CWS) and an Ice Storage System (IS) are selected as possible load shifting methods for further analysis.

CWS is a TES using sensible heat of water to store energy during off-peak hours. Vertical cylinder tanks are the most common shape of tanks used for CWS [4] and they can be located above ground, partially buried or completely buried depending on the location. Tank capacity depends on the amount of cooling load to be stored and temperature difference between stored chilled water and return water. Existing chillers can be used in this method.

Ice storage is a proven technology that reduces chiller size and shifts compressor load, condenser fan and pump loads from peak periods to off-peak periods, where electrical energy is less expensive.

The latent heat of fusion of water (phase change of water to ice or ice to water) is used in this process to store cooling load. Water is used as a phase change storage medium in order to take advantage of its higher storage capacity. In this method it is required to use glycol chillers and heat exchangers.

Following parameters are taken into account when calculating the energy consumption of each method.

- Heat exchanger energy loss 01% [3]
- Ice Storage energy loss 01% [3]
- Chilled Water Storage energy loss 10% [1]

3. Identification of the optimum thermal energy storage required




Figure 4 - Methods of Load Shifting

3.1. Using only Glycol Chillers and Ice Storage Systems




Figure 5 - Ice Storage System with Glycol Chillers Only [3]

3.1.1. Case 01: Shifting both peak and day cooling loads

Only Glycol chillers are used and total peak and day cooling load of 6,403.7 TR_h should be stored during off-peak hours.




Figure 6 - Load Profile of Chiller Shifting Peak and Day using Ice Storage



A Glycol chiller of 1,176.80 TR (936.6 kW) is required for the proposed case and total electrical energy consumption of the chiller is 6,556.5 kWh.

3.1.2. Case 02: Shifting peak cooling load only

Only Glycol chillers are used and peak cooling load of 1,322.0 TRh should be stored during off-peak hours.





Figure 7 - Load Profile of Chiller Shifting Only Peak using Ice Storage

A Glycol chiller of 436.26 TR (347.2 kW) is required for the proposed case and total electrical energy consumption of the chiller is 6,515.6 kWh.

3.2. Using Chilled Water Storage Systems



CH-1, 2 - CONVENTIONAL CHILLI
CP - CONDENSER WATER PUMP

Figure 8 - Chilled Water Storage System

3.2.1. Case 03: Shifting both peak and day cooling loads

Only conventional chillers are used for shifting both the peak and day cooling loads to off-peak hours using chilled water storage system.




Figure 9 - Load Profile of Chiller Shifting Peak and Day using Chilled Water Storage

A conventional chiller of 1,247.49 TR (774.99 kW), which is higher than the existing chiller capacity, is required. Total electrical energy consumption of the chiller is 5,424.9 kWh.

3.2.2. Case 04: Shifting peak cooling load only

Total peak cooling load of 1,322.0 TRh should be stored during off-peak hours using conventional chillers.




Figure 10 - Load Profile of Chiller Shifting Only Peak using Chilled Water Storage

A conventional chiller of 448.94 TR (278.9 kW), having a capacity lower than that of the existing chiller, is required. Hence, no additional chiller is needed. Total electrical energy consumption of the chiller is 5,109.2 kWh.

3.3. Shifting cooling load using ice storage system and conventional chillers




Figure 11 - Ice Storage System with Glycol Chillers and Conventional Chillers

3.3.1. Case 05: Shifting both peak and day cooling loads

Glycol chiller is used only for ice making and conventional chiller is used to meet the cooling load during off-peak hours.




Figure 12 - Load Profile of Chiller Shifting Peak and Day using Ice Storage and Conventional Chiller

A Glycol chiller of 923.96 TR (735.4 kW) and a conventional chiller of 241.20 TR (149.9 kW) are required for the proposed case. Total electrical energy consumption of the chillers is 6,248.1 kWh.

3.3.2. Case 06: Shifting peak cooling load only

Glycol chiller is only used for ice making and conventional chiller is used to meet the cooling load during day and off-peak hours.




Figure 13 - Load Profile of Chiller Shifting Only Peak using Ice Storage and Conventional Chiller

A Glycol chiller of 190.74 TR (151.8 kW) and a conventional chiller of 390.90 TR (242.8 kW) are required for the proposed case. Total electrical energy consumption of the chillers is 5,279.2 kWh.

3.4. Storage Calculation

Storage required to shift peak and day cooling load to off-peak is 6,403.7 TRh and to shift peak cooling load to off-peak is 1,322.0 TRh.

Equation 3 is used to calculate the required storage capacity for chilled water and Equation 4 is used to calculate the required storage capacity for ice storage.

$$V = \frac{X * 12,000 \text{ Btu/Tonhours}}{L * SG * \text{eff} * 1000} * 0.454 \text{ kg/lb} \dots (3)$$

where;

V = TES tank volume, m³

X = amount of thermal capacity required, ton-h

L = latent heat of fusion of ice, Btu/lb

SG = specific gravity, kg/m³

eff = storage efficiency, typically 0.99

$$V = \frac{X * 12,000 \text{ Btu/Tonhours}}{Cp * \Delta T * SG * \text{eff} * 1000} * 0.454 \text{ kg/lb} \dots (4)$$

where;

V = TES tank volume, m³

X = amount of thermal capacity required, ton-h

ΔT = temperature difference, °C

CP = specific heat of water, Btu/lb°c



SG = specific gravity, kg/m³
 eff = storage efficiency, typically 0.90

3.5. Summary

Table 2 - Summary of Six Cases

	Energy Consumption (kWh)			Storage Volume (m ³)
	Chillers	Cooling Towers	Total	
Case 01	6,556.5	262.5	6,819.0	285.57
Case 02	6,515.6	300.0	6,815.6	58.95
Case 03	5,424.9	262.5	5,687.4	832.48
Case 04	5,109.2	300.0	5,409.2	171.86
Case 05	6,248.1	262.5	6,510.6	285.57
Case 06	5,279.2	300.0	5,579.2	58.95

Table 2 summarises the six cases for comparison. Case 02 and Case 06 require lower storage volumes compared to other cases and Case 04 consumes the lowest energy compared to others.

4. Financial Analysis

4.1. Operating Cost

Energy consumption of chiller and cooling towers are considered when calculating the operating cost of the existing system as they are the main components to be replaced when implementing the TES. Table 3 below shows the energy usage as well as the applicable electricity costs during the "Off Peak", "Day" and "Peak" durations.

Table 3 - Per day Operation Cost of the Chiller

TOU	Energy (kWh)	Tariff (LKR/kWh)	Cost (LKR)
Off peak	1,048.9	8.80	9,230.22
Day	3,156.9	13.70	43,250.00
Peak	821.3	22.50	18,478.45
Total	5,027.1		70,958.66

Accordingly, the Table 4 shows the cooling tower's Operating costs for a day.

Table 4 - Per Day Operation Cost of the Cooling Tower

TOU	Energy (kWh)	Tariff (LKR/kWh)	Cost (LKR)
Off peak	105	8.8	924.00
Day	195	13.7	2,671.50
Peak	60	22.5	1,350.00
Total	360		4,945.50

Total Chiller and Cooling Tower power consumption of the existing system is 5,387.1 kWh and per day operation cost is LKR 75,904.16.

4.2. Operating Cost of Proposed cases

Case 01

Storage Capacity = 6,403.7 TRh
 Glycol Chiller = 1,176.8 TR
 Cooling Towers = 5 Nos. of 300 TR
 Operating cost = LKR 60,007.00/day

Total savings per year = LKR 5,802,448.00

Case 02

Storage Capacity = 1,322 TRh
 Glycol Chiller = 436.3 TR
 Cooling Towers = 2 Nos. of 300 TR
 Operating cost = LKR 80,949.00/day

Operating cost of the proposed system is higher than the existing system. Therefore no saving can be expected from this case.

Case 03

Storage Capacity = 6,403.7 TRh
 Glycol Chiller = 1,247.49 TR
 Cooling Towers = 5 Nos. of 300 TR
 Operating cost = LKR 50,049.00/day

Total savings per year = LKR 9,437,068.00

Case 04

Storage Capacity = 1,322 TRh
 Glycol Chiller = 448.9 TR
 Cooling Towers = 2 Nos. of 300 TR
 Operating cost = LKR 65,375.00/day

Total savings per year = LKR 4,335,692.00

Case 05

Storage Capacity = 6,403.7 TRh
 Glycol Chiller = 924 TR
 Conventional Chiller = 241.2 TR
 Cooling Towers = 5 Nos. of 300 TR
 Operating cost = LKR 57,293.00/day

Total savings per year = LKR 6,792,912.00

Case 06

Storage Capacity = 1,322 TRh
 Glycol Chiller = 190.7 TR



Conventional Chiller = 390.9 TR
 Cooling Towers = 2 Nos. of 300 TR
 Operating cost = LKR 65,521.00/day

Total savings per year = LKR 3,789,829.00

4.3. Investment Cost

The main investment is the installation cost of the equipment. Based on market prices prevailed in 2017. Costs used in this study for the financial analysis are shown in Table 5.

Table 5 - Cost of HVAC Equipment (Year 2017)

Item	Capacity		Price (LKR)
Glycol Chiller	200	TR	13,500,000.00
Glycol Chiller	300	TR	22,000,000.00
Conventional Chiller	100	TR	7,500,000.00
Conventional Chiller	150	TR	10,500,000.00
Conventional Chiller	200	TR	13,000,000.00
Conventional Chiller	300	TR	18,000,000.00
Conventional Chiller	450	TR	26,000,000.00
Ice Storage	250	TRh	2,225,000.00
Chilled Water S	1	m ³	55,000.00
Heat Exchanger	200	RT	2,150,000.00
Heat Exchanger	420	RT	3,635,000.00
Cooling Tower	350	TR	2,200,000.00
Pumps	1		500,000.00
Pipe work	1	m	10,000.00
Insulation	1	m ³	3,600.00

4.4. Benefits to the Industry

The customers will be benefited through shifting their peak time energy usage to off-peak period due to the TOU tariff offered by the CEB.

To evaluate the viability of the investment, simple payback period for the investment and project IRR (Internal Rate of Return) was calculated.

For calculating the IRR following parameters were considered.

- Project life time = 20 years
- Resale value after 20 years = 40% (for chillers only)
- Debt: Equity ratio = 70:30
- Loan period = 07 years
- Loan interest = 16%

Summary of financial analysis done for six cases is shown in Table 7.

Table 6 - Summary of financial analysis

	Total Investment (MLKR)	Savings Per Year (MLKR)	Simple Pay back	Project IRR
Case 01	173.52	5.80	29.90	(0.21%)
Case 02	-	(1.84)	-	-
Case 03	106.46	9.44	11.28	6.78%
Case 04	10.53	4.34	2.43	40.76%
Case 05	146.48	6.79	21.56	1.52%
Case 06	30.70	3.79	8.10	10.78%

4.5. Utility Benefits

Benefits to the utility can be calculated using avoided cost method. Data from system control centre of Ceylon Electricity Board (CEB) shows that usually 115MW, GT7 Gas turbine at Kelanitissa power station, 160MW, combined cycle AES Kelanitissa power station and 300MWX3, Lakvijaya coal power station are in the merit order dispatch margin during Peak, Day and Off-peak periods. Therefore, energy reduction in peak period is considered to be reduced from GT 7 and reduction in the day period is considered to be from AES power plant. Energy increase in the off-peak period due to shifted load is considered to be from Lakvijaya coal power station.

The operating costs of these power plants are shown in Table 7.

Table 7 - Unit Cost of Power Plant (2017 prices)

Power Plant	Unit Cost (LKR/kWh)
GT7	47.56
AES	22.45
Lakvijaya	7.32

Project IRR was calculated from the utility side for the above six cases expecting investment will be done by the utility.

Table 8 - Calculated Project IRR from Utility side

	Savings Per Year (LKR)	Simple Pay back (years)	Project IRR
Case 01	26,245,868.00	6.61	13.85%
Case 02	-	-	-
Case 03	28,444,737.00	3.74	26.05%
Case 04	11,855,498.00	0.89	112.50%
Case 05	26,245,868.00	5.58	16.86%
Case 06	11,401,561.00	2.69	36.67%



From Table 8, it can be seen that Cases 3, 4 and 6 are financially viable and Case 4 presents a very attractive option.

The benefits gained from shifting AC load to the utility are not only limited to reducing cost of power generation. Some of the benefits which were not considered into the calculation are:

- Delay in the investment costs on new power plants that will be required if demand is not reduced.
- Delay in the investment on transmission and distribution upgrades.
- Efficiency improvement of the coal power plants during off-peak time through the increased demand and avoiding of de-loading the units.
- Increase in the system stability.

5. Conclusions

CWS with shifting only the peak cooling load to off-peak hours is the best TES solution for the Cinnamon Lakeside Hotel because no additional chillers are required. Space limitations should also be considered when selecting a TES system. Shifting only peak cooling load to off-peak also requires less storage capacity compared to shifting both peak and day cooling loads.

Simple payback of 2.43 years and project IRR of 40.76% for case 04 are good financial indicators for a project. These figures will attract investors on TES shifting peak cooling load to off-peak hours using CWS system.

Ice storage systems will increase the temperature difference between return water and chilled water. This will reduce the chilled water flow rate required to meet the cooling load of the building. Reduction of the chilled water flow rate will reduce the pump and fan motor sizes which reduce the energy consumption and investment of the HVAC system. Ice storage system will also reduce the duct and pipe sizes due to high temperature difference achieved between chilled water and return water.

Implementing an ice storage system at the construction stage of a hotel will reduce the investment on HVAC system due to the reduction of equipment sizes, duct work and pipe diameter sizes. This would also reduce the

total energy consumption of HVAC system due to reduction of equipment sizes. Implementing the ice storage system at the initial stage of construction could give high project IRR for case 06 which would attract investors.

Shifting only peak cooling load to off-peak hours at the selected hotel will reduce the utility peak demand by 205 kW. If this can be projected to 50 similar capacity buildings, utility can achieve 10 MW peak shavings.

References

1. ASHRAE Handbook, "HVAC Systems and Equipment, 2012", 2012.
2. Eskom Integrated Demand Management, Escom Holdings SOC Ltd, "Heating, Ventilation and Air Conditioning (HVAC) Systems: Energy-Efficient Usage and Technologies", July 2015.
3. EVAPCO, INC, 5151 Allendale Lane, Taneytown, MD 21787, "Thermal Ice Storage, Application and Design Guid", 2007.
4. Kristoper L. Kinney, Eng. Lock Lee, "A Showcase for Energy Efficient Hotels in South Asia".
5. Transmission & Generation Planning Branch, Transmission Division, Ceylon Electricity Board - Sri Lanka, "Long term generation expansion plan 2018-2037", 2017.